

The Corporation of the Township of Bonnechere Valley
Water and Sewage Department

Report to Public Works Committee

March 2025

1: Water Operations

- A - The Eganville Drinking Water System continues to operate in full compliance with all requirements.
- B - The Coating Contractor is on Site preparing for the recoating of the GAC Filters Compartments
- C – The 2024 Annual Compliance report for the Water Treatment Plant is completed
- D – Located and hand shoveled out the fire hydrants twice in the month of February
- E – Irvcon Heating & Air Conditioning is on site working the heating system in the Water Plant we have not had heat in the office & lab for 3 weeks

2: Wastewater Operations

A - The Eganville Wastewater System continues to operate in full compliance According to the Provincial Guidelines that is set out in the C of A

B – A new set of Double Doors were installed on the Chemical Building

C – The 2024 Annual Compliance report for the Wastewater Plant and the Bio – Solids is completed.

D – The 4 Quarter report for the Wastewater Plant was completed and sent to Environment Canada

Respectfully Submitted Daryl Verch